



November 04, 2019

Christopher Wider, Chairman

Town of Norfolk – Zoning Board of Appeals
One Liberty Lane
Norfolk, MA 02056

Re: Norfolk, MA – The Residences at Norfolk Station
194 Main Street
Comprehensive Permit Peer Review

Dear Chairman Wider:

BETA Group, Inc. (BETA) has completed its peer review of the landscape design elements of the site plans and supporting engineering documents for the above-referenced project, based on the following materials:

- Application for Comprehensive Permit, The Residences at Norfolk Station, dated December 13, 2018;
- Stormwater Management Report, The Residences at Norfolk Station, 194 Main Street, Norfolk MA, dated August 23, 2018 prepared by Zenith Engineering Consultants, LLC;
- Comprehensive Permit Plan, The Residences at Norfolk Station. 194 Main Street, Norfolk MA, plan set, twenty (20) sheets, dated August 29, 2018 prepared by Zenith Engineering Consultants, LLC;
- Fire Department Memorandum dated January 9, 2019 from Chief Cole Bushnell, Norfolk Fire Department;
- Fire Department Memo dated September 26, 2018 from Chief Cole Bushnell, Norfolk Fire Department;
- Conservation Commission comment email dated September 18, 2018;
- Norfolk Town Planner letter to the Norfolk ZBA dated October 11, 2018;
- Norfolk Town Planner letter to the MassHousing Comprehensive Permit Program dated June 7, 2018
- MassDEP Stormwater Management Standards (SMS)

We note that a revised set of plans was submitted on October 31, 2019. While there are some revisions on these plans the landscape design is essentially the same as the previous plan set.

The following are our comments on the plans. Where referenced, the term “applicant” refers to either the applicant itself or its design consultants, and Section references are to the Norfolk ‘Rules & Regulations for Subdivision of Land & Site Plan Approval,’ amended September 16, 2010 (referred to herein as the Subdivision/Site Plan Regulations) or the ‘Zoning Bylaws with Amendments Through May 2014’ (referred to herein as the Zoning Bylaws).

General

The existing site is developed. The site fronts Main Street and the MBTA Commuter Rail. Significant wooded areas abut the northern and eastern property lines.

- L1 Consider providing entrance features such as stone walls, decorative fencing, up-lighting, and additional plantings to both sides of the entrance driveway near Main Street. These should be placed to avoid sightline impacts.
- L2 Consider provide vegetative screening as well as the proposed fencing along the west side of the main entrance drive. The height and type of fence should be labeled on the layout plan.
- L3 The existing stone wall along the northern property line should be labeled to be protected and retained.
- L4 If feasible, relocate the proposed maintenance building and the dog play area to be approximately 15-20 feet off the stone wall. This will allow existing landforms and vegetation to remain.
- L5 The northern portion of the project site is heavily wooded. The proposed 64 cypress trees may not be needed along the entire northern property line. The main area of additional screening would be at the eastern under building parking entrance/exit and the northeast end of the proposed building. The grading along the northerly property line should be reviewed to evaluate how much of the existing vegetative screening can be maintained.
- L6 Relocate the proposed bicycle parking area to be adjacent to the proposed walkway that leads from the building to the parking lot. The bike rack should be set on a concrete pad.
- L8 Provide native plantings between the east end of the building and the proposed stormwater basin; include multi-stemmed tree (Amelanchier and Birch), and a mix of evergreen and deciduous shrubs (Bayberry, Winterberry, Inkberry, Chokeberry, Silky Dogwood, etc.).
- L9 Provide native seed mix containing a mix of herbaceous perennials and grasses for stormwater basin slopes, edges, and those areas not intended to be a mown lawn.
- L10 Provide a more extensive vegetative screening along the MBTA Commuter line. Use a mix of native evergreen and deciduous trees and shrubs.
- L11 Show and label existing trees to remain (trunk location, caliper and branch spread) along Main Street.
- L12 Consider additional shrub plantings along both sides of the proposed walk that connects Main Street and the main building entrance.
- L13 Provide native plantings between the south side of the building and the proposed stormwater basin along Main Street. Refer to comment L8 for plant information.
- L14 Consider adding 3 deciduous shade trees on each side of the main building entrance along the south face of the building. This will help shade the building during the summer months and provide a bit of screening from the roadway.
- L15 Coordinate the foundation planting with the expansive exposed building foundations along the south east end of the front of the proposed building. The foundation planting will need to be coordinated with the louvers along the south east end of the front of the proposed building.

Christopher Wider, Chairman

November 4, 2019

Page 3 of 3

- L16 Dwarf Japanese Maple is not an appropriate plant for the end islands within the parking lot, at the garage entrance/exit and at the green spaces at the pedestrian entrance/exit from the building. Provide an upright tree underplanted with low shrubs and ground covers for these areas.
- L17 Consider low plantings along the rear building face instead of just stone; coordinate any planting with the louvers.
- L18 Provide accessible walkway from the parking lot to the activity areas in the rear of the site. It is noted that the revised plan submitted on 10/31/2019 included walkways within this area. We have not had the opportunity to review this.
- L19 Specified plant material. Consider specifying 2 or 3 native evergreens for screening instead of the Leyland cypress. The Town requires a minimum of 3-inch caliper for the deciduous trees. Expand the tree and shrub palette to include other native plants.
- L20 Planting Details. Remove trunk wrapping; it is not required for most trees.

If you have questions about any of the preceding comments, please feel free to contact either myself at (401) 333-2382 or Scott Ridder at 978-255-1982.

Very truly yours,

BETA Group, Inc.



William P. McGrath, P.E.
Senior Associate

cc: