



NORFOLK FIRE DEPARTMENT

117 MAIN STREET
NORFOLK, MASSACHUSETTS 02056

COLEMAN C. BUSHNELL
FIRE CHIEF

TELEPHONE 508-528-3207
FAX 508-520-9762

MEMO

TO: Mr. Ray Goff, Town Planner

FROM: Cole Bushnell, Chief

DATE: August 26, 2016

SUBJ: LAKELAND FARMS

The applicant for LAKELAND FARMS has submitted a revised site access plan for fire apparatus, which includes a wider entry cut back of 30' to facilitate enhancing fire apparatus approach to the entrance.

Furthermore the applicant has submitted the completed 527 CMR 1.00: MASSACHUSETTS COMPREHENSIVE FIRE SAFETY CODE, NFPA-1, '12 ed., Chapter 18 Fire Department Access and Water Supply, Chapter 18, which complies with all aspects of the regulations for sub division development.

Fire Department reserves the right under the regulation to determine if FIRE LANE NO PARKING signage/road painting will be needed based upon site inspection post-construction.

Should blasting be required for this area, the developer/contractor will be required to file all required Permitting with the Fire Department. Also prior to blasting, the developer/contractor shall provide sufficient notification for scheduling on-site coverage to monitor the blasting. All costs associated with the coverage provided by the Fire Department shall be the responsibility of the developer/contractor. Checks for blasting details shall be issued prior to any blasting.

Should the developer/contractor have any questions regarding the input from the Fire Department or if you should need clarification of these comments, please do not hesitate contacting the Office at your convenience.