



Norfolk DPW - Water Division 2010

PWS ID: #2208000

REPORT ON WATER QUALITY

FOR A LARGE PRINT VERSION OF THIS REPORT, PLEASE REFER TO OUR WEBSITE, www.virtualnorfolk.org

The Norfolk Department of Public Works (DPW) is pleased to provide you with this 2010 Report on Water Quality. The Norfolk DPW continuously strives to produce the highest quality water possible to meet or surpass everyday water quality standards. We are committed to supplying our customers with a safe and adequate water supply at reasonable cost.

In order to ensure that tap water is safe to drink, the Department of Environmental Protection (DEP) and the Environmental Protection Agency (EPA) prescribe regulations that limit the amount of certain contaminants in water provided by Public Water Systems (PWS). The standards we operate under were enacted by the U.S. Congress as the Safe Drinking Water Act (DWA) of 1974, and were amended in 1986 and 1996. The Food and Drug Administration (FDA) and the Massachusetts Department of Public Health (MDPH) regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

We encourage public interest and participation in our community's decisions affecting drinking water. Meeting dates for the Board of Selectmen are posted at the Town Hall and published on the town's website, www.virtualnorfolk.org. The Norfolk DPW is located at 33 Medway Branch Road, off of Boardman Street. If you would like to know more about the Norfolk water supply, or if you are interested in participating the decision making process, please contact us at (508) 528-4990 with questions, comments or concerns.

In 2010 a supplement well (04G) was installed at the Spruce Road well site, and the original Spruce Road well (02G) was rehabilitated to increase the available capacity of the well. Combined, the two wells are capable of producing about 400 gallons per minute. This was a necessary step to insure sufficient water supply for the Town of Norfolk.

The necessary forms and applications to permit the supplement well at Gold Street (#1A) as a permanent source of supply were submitted to MassDEP. However, due to the higher levels of iron and manganese in this well, the source would have to be treated for removal of these organics before the town received approval. Due to the cost associated with this treatment, we felt it was not a viable option at this time.

The Water Division continues to work closely with our consultants to locate additional leaks. The town has continuously brought in leak detection experts and is working diligently to have the leaks repaired. In the spring of 2011, the town will use a grant received by the MassDEP to conduct leak detection using some newer more sophisticated equipment. We are confident this will just improve our ability to find leaks and repair them in a timely manner.

The Water Division continues to work closely with our consultants to locate additional water supplies to improve the redundancy and overall reliability of the water system. We have been meeting with the surrounding towns to discuss improvements and possible changes to interconnection to ensure the Town of Norfolk has adequate, quality water for its residents.

Please keep in mind that during the long hot summer months all residents should do their best to conserve water. The Town of Norfolk Water Division is currently in a water ban. All information regarding this ban can be found on the town's website or by calling our office at 508-528-4990. We thank everyone in advance for your continued adherence.

Water Source & Treatment

Norfolk's water is supplied from four gravel-packed wells that draw from the Charles River Watershed. Gold Street Wells, 2208000-01G and 2208000-01AG, which are located near the intersection of Medway Street and Myrtle Street; and the Spruce Road Well, 2208000-02G and 2208000-04G, located at the intersection of Mirror Lake Avenue and Spruce Road.

Your water is delivered to your home through 57 miles of water main and stored in two 1.0 million gallon storage tanks. The Pondville Tank is located off Sharon Avenue, and the Weeber Tank is located off Meetinghouse Road behind Town Hall.

In addition, the Town of Norfolk maintains permanent interconnections with the Town of Wrentham, the Wrentham Development Center, the Town of Franklin, and MCI Norfolk. Additional emergency interconnections are maintained with the towns of Walpole and Medfield.

In order to meet state and federal requirements for public drinking water, our source water receives treatment before it is supplied to our customers. The pH of the water at both well locations is increased with sodium hydroxide to reduce its corrosiveness in household plumbing and a polyphosphate is added to sequester iron and manganese, as well as to coat the water mains to assist with corrosion control. At Spruce Road, aeration removes dissolved CO₂, thus raising pH and reducing radon, and is disinfected with a state-of-the-art UV (ultraviolet) light system. Testing throughout the water system has shown that this treatment has been effective at reducing lead and copper concentrations. Emergency chlorination systems are also available at all locations. All chemicals are approved for water treatment by one or more of the following organizations: National Sanitation Foundation International (NSF), or UL, both accredited by the American National Standards Institute (ANSI). Chemicals also have to meet performance standards established by the American Water Works Association.

NORFOLK WATER DEPARTMENT 2010 CCR TABLES

The following results were from sampling done in 2010 or during the most recent monitoring period for each contaminant group.

Inorganic Contaminants	Date(s) Collected	MCL	MCLG	Highest Result	Detected Range	Major Sources	Violation (Y/N)
Nitrate (ppm)	6/03/10 9/28/10	10	10	3.0	1.2 - 3.0	Runoff from fertilizer use; leaching from septic tanks; natural deposits	N
Barium (ppm)	9/28/10	2	2	0.039	--	Erosion of natural deposits	N
Fluoride (ppm)	9/28/10	4	4	0.10	--	Erosion of natural deposits	N
Perchlorate (ppb)	9/28/10	2	--	0.16	--	Rocket propellants, fireworks, munitions, flares, blasting agents	N

Radioactive Contaminants	Date(s) Collected	MCL	MCLG	Highest Result	Detected Range	Major Sources	Violation (Y/N)
Gross Alpha (pCi/l)	9/28/10 11/30/10	15	0	0.64	0.0 – 0.64	Erosion of natural deposits	N
Radium 226 & 228 (pCi/l)	9/28/10 11/30/10	5	0	0.92	0.0 – 0.92	Decay of natural and manmade deposits	N
Beta Particles (pCi/l)	11/30/10	50*	0	2.17	--	Decay of natural and manmade deposits	N

* The MCL for beta particles is 4 mrem/yr. EPA considers 50 pCi/l to be the level of concern for beta particles.

Lead and Copper*	DATE COLLECTED	90 th PERCENTILE	Action Level (AL)	MCL G	# SITES TESTED	# SITES ABOVE AL	TYPICAL SOURCE OF CONTAMINATION	Exceeds AL (Y/N)
Lead (ppb)	11/15 – 11/22/10	2.0	15	0	41	0	Corrosion of household plumbing systems	N
Copper (ppm)	11/15 – 11/22/10	0.5	1.3	1.3	41	0	Corrosion of household plumbing systems	N

*Lead and copper compliance is based on the 90th percentile value, which is the highest level found in 9 out of every 10 homes sampled. This number is compared to the action level for each contaminant.

Unregulated and Secondary Contaminants	Date Collected	Highest Detection	Average	SMCL	ORSG	Possible Sources
Sulfate (ppm)	5/20/08	12	11.5	250	--	Natural sources
Sodium* (ppm)	9/28/10	59	--	--	20	Natural sources; runoff from road salt
Manganese **(ppm)	6/1/10 6/3/10 9/28/10	289	191	50	--	Erosion of natural deposits
Radon*** (pCi/l)	9/28/10	250	--	--	10,000	Natural sources

*Sodium-sensitive individuals, such as those experiencing hypertension, kidney failure, or congestive heart failure, should be aware of the levels of sodium in their drinking water where exposures are being carefully controlled.

**EPA has established a lifetime health advisory (HA) of 300 ppb for manganese to protect against concerns of potential neurological effects, and a one day and 10 day HA of 1,000 ppb for acute exposure.

***Radon is an odorless, tasteless gas that occurs naturally from the breakdown of uranium in soil. Radon can enter a home through cracks in the foundation. Radon can also get into indoor air when released from tap water. The current guidance for radon in drinking water in Massachusetts is 10,000 picocuries per liter (pCi/l). Typically this would result in an increase of 1 pCi/l to the air inside the home. EPA currently advises people to take action if the total level of radon in their household air is above 4 pCi/l. Breathing in radon gas over a long period of time can increase your risk of getting lung cancer. Drinking tap water containing high amounts of radon may increase your chances of developing stomach cancer. For more information about radon, contact the EPA at 1-800-SOS-RADON.

NORFOLK WATER DEPARTMENT - 2010 CCR TABLES (cont'd)

Bacteria	Highest # of Positive Samples in a Month	MCL	MCLG	Possible Sources	Violation (Y/N)
Total Coliform Bacteria	2	1	0	Naturally present in the environment	Y
E.coli	0	*	0	Human and animal fecal waste	N

*Compliance with the E. coli MCL is determined upon additional repeat testing.

On August 3, 2010 total TC was detected at Spruce Road Well #1. In response to that detection repeat samples were taken at the well and in the distribution system at the tanks. A second detection at Sharon Ave Tank prompted immediate chlorination of the system. All samples taken during and after chlorination were negative for TC and EColi.

On September 30, 2010 TC was detected at the Sharon Ave Tank. After determining the possible cause of the TC contamination, the town began immediate chlorination of the system during and until the construction project on Pond Avenue and Route 115 was completed. All TC samples taken during and after the chlorination were negative for TC and EColi.

WATER QUALITY SUMMARY: Although we ran hundreds of tests, we only listed the substances that were at or above detection limits. Unless otherwise noted, sample dates are for the year 2010 or within 5 years if we were not required to test in 2010 for previously detected contaminants.

Is Our Water Safe for Everyone?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Terms and Abbreviations used in the Table:

AL = Action Level – The concentration of a contaminant that, if exceeded, triggers treatment or other requirements, which a water system must follow.

MCL = Maximum Contaminant Level – The highest level of a contaminant in drinking water. MCLs are set as close to the MCLGs (see below) as feasible using the best available treatment technology.

MCLG = Maximum Contaminant Level Goal – The level of a contaminant in drinking water below, which there is no known expected risk to health. MCLGs allow for a margin of safety.

Total Coliform = A bacteria that indicates other potentially harmful bacteria may be present.

Unregulated contaminants – These are substances without MCLs for which EPA requires monitoring. For some of these substances, the Massachusetts Office of Research and Standards (ORS) has developed state guidelines or secondary MCLs.

SMCL = Secondary Maximum Contaminant Level – Standards are developed to protect the aesthetic qualities of drinking water and are not health based.

ORSG = Massachusetts Office of Research and Standards Guideline – This is the concentration of a chemical in drinking water, at or below which, adverse, non-cancer health effects are likely to occur after chronic (lifetime) exposure. If exceeded, it serves as an indicator of the potential need for further action.

pCi/l = Picocuries per liter (measure of radioactivity)

ppm = Parts per million, or milligrams per liter (mg/l)

ppb = Parts per billion, or micrograms per liter (ug/l)

mrem/yr = millirems per year (a measure of radiation absorbed by the body)

90th Percentile = The highest value found out of 90 percent of the samples taken in a representative group. Nine out of every 10 homes sampled were at or below this level.

Contamination from Cross Connection:

Cross-connections that could contaminate drinking water distribution lines are a major concern. A cross-connection is formed at any point where a drinking water line connects to equipment (boilers), systems containing chemicals (air conditioning systems, fire sprinkler systems, irrigation systems) or water sources of questionable quality. Cross-connection contamination can occur when the pressure in the equipment or system is greater than the pressure inside the drinking water line (backpressure). Contamination can also occur when the pressure in the drinking water line drops due to fairly routine occurrences (main breaks, heavy water demand), causing contaminants to be sucked out from the equipment and into the drinking water line (backsiphonage).

Outside water taps and garden hoses tend to be the most common sources of cross-connection contamination at home. The garden hose creates a hazard when submerged in a swimming pool or when attached to a chemical sprayer for weed killing; garden hoses that lay on the ground may be contaminated by fertilizers, cesspools or garden chemicals. We recommend the installation of hose bibb type vacuum breakers on all outside spigots. This will protect you, the homeowner, against the potential cross connection contamination of your outside garden hose.

Community water supplies are continually jeopardized by cross-connection unless appropriate valves, know as backflow prevention devices, are installed and maintained. The Town of Norfolk has an active cross connection control program. We survey all industrial, commercial and institutional facilities in the service area to insure that all potential cross-connections are identified and eliminated or protected by a backflow preventer, and test all backflow devices as required by Mass DEP and the Cross Connection Control Section (310 CMR 22.22) of the Commonwealth of Massachusetts Drinking Water Regulations that they are providing maximum protection.

SWAP (Source Water Assessment and Protection):

The Massachusetts DEP has prepared a Source Water Assessment Program (SWAP) Report for Norfolk DPW. The report assesses the susceptibility of public water supplies to contamination and makes recommendations. This report is available from WhiteWater, Inc. located at 253B Worcester Road, Charlton, MA, Norfolk DPW, Board of Health and also at the DEP website: www.state.ma.us/dep/water/drinking/swapreps.htm.

A susceptibility ranking of **high** was assigned to both wells in our system by the DEP due to the absence of hydro-geologic barriers (i.e. clay). Both Spruce Road and Gold Street wells are gravel-packed and presently meet all US Environmental Protection Agency (EPA) and MA DEP drinking water quality standards.

A well's water supply protection area is the land around the well where protection activities should be focused. Each well has a Zone I protective radius (400 ft) and a Zone II protection area. Zone I is owned and controlled by the Norfolk DPW and limited to only water supply activities. Zone II is defined as the primary recharge area for each well. To ensure wellhead protection, all construction plans in Norfolk are reviewed by the DPW with emphasis given to those in close proximity to Zone II.

In concert with its certified operator, WhiteWater, Inc., the Norfolk DPW is addressing the concerns as stated in the SWAP Report and welcomes your input to our planning. If you have any questions please contact Robert J. McGhee, Interim Director of Public Works, at (508) 528-4990.

TOWN OF NORFOLK
Department of Public Works
33 Medway Branch
Norfolk, MA 02056

BULK RATE
U.S. POSTAGE PAID
Norfolk, MA
10 Permit # 12
ECRWSS

POSTAL PATRON

NORFOLK, MA 02056

Sources of Drinking Water and Drinking Water Contaminants:

The sources of drinking water in the United States (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals can be naturally-occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, and farming.
- **Pesticides and herbicides**, may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- **Organic chemical contaminants**, include synthetic and volatile organic chemicals that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- **Radioactive contaminants** can be naturally occurring or be the result of oil and gas production, and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contamination. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791) or the Massachusetts Department of Environmental Protection (DEP) 617-292-5885. www.state.ma.us/dep

Department of Public Works Contact Information:

The Norfolk water system is operated and maintained by the Department of Public Works, Water Division. If you have any questions about this report, please contact: Robert J. McGhee, Interim Director of Public Works at 508-528-4990.

Department of Public Works, 33 Medway Branch Road, Norfolk, MA 02056; office hours are Monday through Friday; 8:00 am to 3:30 pm; 508-528-4990. For water problems outside of normal hours, please contact the Norfolk Police Department at 508-528-3206 and one of our representatives will contact you immediately.